



BCA Green Mark for New Non-Residential Buildings Version NRB/4.1

Framework - BCA Green Mark for New Non-Residential Buildings (Version NRB/4.1)

To achieve Green Mark Award



Pre-requisite Requirement

All relevant pre-requisite requirements for the specific Green Mark Rating are to be complied with



Energy Related Requirements
Minimum 30 points

Other Green Requirements
Minimum 20 points

Elective Requirement for Energy Improvement
(Combination of the following items to meet 30 points)

Part 1 - Energy Efficiency

- Air-con { 1-1 Thermal Performance of Building Envelope - ETTV
- 1-2 Air-Conditioning System
- Non Air-con { 1-3 Building Envelope – Design/Thermal Parameter
- 1-4 Natural Ventilation / Mechanical Ventilation
- 1-5 Daylighting
- 1-6 Artificial Lighting
- 1-7 Ventilation in Carparks
- General { 1-8 Ventilation in Common Areas
- 1-9 Lifts and Escalators
- 1-10 Energy Efficient Practices & Features
- 1-11 Renewable Energy

Elective Requirement from Other Areas
(Combination of the following items to meet 20 points)

Part 2 - Water Efficiency

- 2-1 Water Efficient Fittings
- 2-2 Water Usage and Leak Detection
- 2-3 Irrigation System and Landscaping
- 2-4 Water Consumption of Cooling Towers

Part 3 – Environmental Protection

- 3-1 Sustainable Construction
- 3-2 Sustainable Products
- 3-3 Greenery Provision
- 3-4 Environmental Management Practice
- 3-5 Green Transport
- 3-6 Refrigerants
- 3-7 Stormwater Management

Part 4 - Indoor Environmental Quality

- 4-1 Thermal Comfort
- 4-2 Noise Level
- 4-3 Indoor Air Pollutants
- 4-4 Indoor Air Quality (IAQ) Management
- 4-5 High Frequency Ballasts

Part 5 – Other Green Features

- 5-1 Green Features and Innovations

Point Allocations - BCA Green Mark for New Non-Residential Buildings (Version NRB/4.1)

Category			Point Allocations	
(I) Energy Related Requirements				
Minimum 30 points	Part 1 : Energy Efficiency			
	NRB 1-1 Thermal Performance of Building Envelope - ETTV	Section (A) Applicable to air-con areas	12	
	NRB 1-2 Air-Conditioning System		30	
	Sub-Total (A) – NRB 1-1 to 1-2			42
	NRB 1-3 Building Envelope – Design/Thermal Parameter	Section (B) Applicable to non air-con areas excluding carparks and common areas	35	
	NRB 1-4 Natural Ventilation / Mechanical Ventilation		20	
	Sub-Total (B) – NRB 1-3 to 1-4			55
	NRB 1-5 Daylighting	Section (C) Generally applicable to all areas	6	
	NRB 1-6 Artificial Lighting		12	
	NRB 1-7 Ventilation in Carparks		4	
	NRB 1-8 Ventilation in Common Areas		5	
NRB 1-9 Lifts and Escalators	2			
NRB 1-10 Energy Efficient Practices & Features	12			
NRB 1-11 Renewable Energy	20			
Sub-Total (C) – NRB 1-5 to 1-11			61	
Category Score for Part 1 – Energy Efficiency Prorate Subtotal (A) + Prorate Subtotal (B) + Prorate Subtotal (C)			116 (Max)	
(II) Other Green Requirements				
Minimum 20 points	Part 2 : Water Efficiency			
	NRB 2-1 Water Efficient Fittings		10	
	NRB 2-2 Water Usage and Leak Detection		2	
	NRB 2-3 Irrigation System and Landscaping		3	
	NRB 2-4 Water Consumption of Cooling Towers		2	
	Category Score for Part 2 – Water Efficiency			17
	Part 3 : Environmental Protection			
	NRB 3-1 Sustainable Construction		10	
	NRB 3-2 Sustainable Products		8	
	NRB 3-3 Greenery Provision		8	
	NRB 3-4 Environmental Management Practice		7	
	NRB 3-5 Green Transport		4	
	NRB 3-6 Refrigerants		2	
	NRB 3-7 Stormwater Management		3	
	Category Score for Part 3 – Environmental Protection			42
	Part 4 : Indoor Environmental Quality			
	NRB 4-1 Thermal Comfort		1	
	NRB 4-2 Noise Level		1	
	NRB 4-3 Indoor Air Pollutants		2	
NRB 4-4 Indoor Air Quality (IAQ) Management		2		
NRB 4-5 High Frequency Ballasts		2		
Category Score for Part 4 – Indoor Environmental Quality			8	
Part 5 : Other Green Features				
NRB 5-1 Green Features & Innovations		7		
Category Score for Part 5 – Other Green Features			7	
Green Mark Score :			190 (Max)	

BCA Green Mark Award Rating and Prerequisite Requirements

Green Mark Score	Green Mark Rating
90 and above	Green Mark Platinum
85 to < 90	Green Mark Gold ^{Plus}
75 to < 85	Green Mark Gold
50 to <75	Green Mark Certified

Prerequisite Requirements for Non-Residential Building Criteria

Air-Conditioned Buildings

- (1) Building envelope design with Envelope Thermal Transfer Value (ETTV) computed based on the methodology and guidelines stipulated in the Code on Envelope Thermal Performance for Buildings and this Standard.

Green Mark Gold^{Plus} – ETTV of 42 W/m² or lower

Green Mark Platinum – ETTV of 40 W/m² or lower

- (2) To demonstrate the stipulated energy savings over its reference model using the energy modeling framework set out in Appendix E of the Certification Standard. Details and submission requirements on energy modeling can be found in Appendix E.

Green Mark Gold^{Plus} – At least 25% energy savings based on energy efficiency measures and improvements that reduce cooling load requirements

Green Mark Platinum – At least 30% energy savings based on energy efficiency measures and improvements that reduce cooling load requirements

- (3) Prescribed Design System Efficiency (DSE) of building cooling systems to be as follows:

(i) For Buildings using Water-Cooled Chilled-Water Plant:

Green Mark Rating	Peak Building Cooling Load (RT)	
	< 500	≥ 500
	Minimum Design System Efficiency ⁽¹⁾ DSE (kW/RT)	
Certified	0.80	0.70
Gold	0.80	0.70
Gold ^{Plus}	0.70	0.65
Platinum	0.70	0.65

Related Criteria

NRB 1-1 – Thermal Performance of Building Envelope

NRB 1-2(a) – Air-Conditioning System

Prerequisite Requirements for Non-Residential Building Criteria – Cont'd

(ii) For Buildings using Air Cooled Chilled-Water Plant or Unitary Air-Conditioners:

Green Mark Rating	Peak Building Cooling Load (RT)	
	< 500	≥ 500
	Minimum Design System Efficiency ⁽¹⁾ DSE (kW/RT)	
Certified	0.90	0.80
Gold	0.90	Not applicable ⁽²⁾
Gold ^{Plus}	0.85	
Platinum	0.78	

Important notes :

(1) The efficiency of the overall air-conditioning system shall meet its design system efficiency as well as the corresponding minimum DSE stipulated for the respective air-conditioning system and Green Mark rating during the building operating hours specified below:

<p>Office Buildings: Monday to Friday : 9 a.m. to 6 p.m.</p> <p>Retail Malls : Monday to Sunday :10 a.m. to 9 p.m.</p>	<p>Hotels: Monday to Sunday : 24 Hours</p> <p>Other Building Types: To be determined based on operating hours</p>
--	---

(2) For building with peak building cooling load of more than 500 RT, the use of air cooled chilled-water plant or unitary air-conditioners are not applicable for Gold and higher ratings. In general, the system efficiency of the air cooled central chilled-water plant and other unitary air-conditioners are to be comparable with the stipulated efficiency for water-cooled central chilled-water plant. Buildings that are designed with air cooled systems and for higher Green Mark rating will be assessed on a case by case basis.

- (4) Instrumentation for monitoring the water cooled chilled-water plant efficiency is to be provided in accordance with the requirement set in the criteria.
- (5) Minimum score under NRB 3-1 Sustainable Construction
Green Mark Gold^{Plus} ≥ 3 points
Green Mark Platinum ≥ 5 points
- (6) Minimum score under NRB 3-2 Sustainable Products
Green Mark Gold^{Plus} ≥ 3 points
Green Mark Platinum ≥ 4 points

Related Criteria

NRB 1-2(b) – Air-Conditioning System

NRB 1-2(d) – Air-Conditioning System

NRB 3-1 – Sustainable Construction

NRB 3-2 – Sustainable Products

Prerequisite Requirements for Non-Residential Building Criteria – Cont'd

Non Air-Conditioned Buildings

- (7) To be eligible for Green Mark Platinum rating, it is a requirement to use ventilation simulation modeling and analysis to identify the most effective building design and layout. The simulation results and the recommendations derived are to be implemented to ensure good natural ventilation with minimum weighted average wind velocity of 0.6 m/s within the units. Details and submission requirements on ventilation simulation can be found in Appendix C of the Certification Standard.
- (8) Minimum score under NRB 3-1 Sustainable Construction
 Green Mark Gold^{Plus} ≥ 3 points
 Green Mark Platinum ≥ 5 points
- (9) Minimum score under NRB 3-2 Sustainable Products
 Green Mark Gold^{Plus} ≥ 3 points
 Green Mark Platinum ≥ 4 points

Related Criteria

NRB 1-4(a)(ii) –
Natural
Ventilation

NRB 3-1 –
Sustainable
Construction

NRB 3-2 –
Sustainable
Products

Building Developments with more than 30% Non Air-Conditioned Spaces

- (10) Prerequisite requirement for building developments with a combination of ventilation mode and with aggregate non-air-conditioned spaces of more than 30% of the total constructed floor areas (excluding carparks and common areas) are as follows :

Aggregate Non Air-Conditioned Spaces (m ²)	Aggregate Air-Conditioned Spaces (m ²)	Ventilation Simulation Requirement See Note (a)	Energy Modeling Requirement See Note (b)	Justification on Energy Savings See Note (c)
≥ 2000	≥ 5000	Yes	Yes	No
< 2000	≥ 5000	No	Yes	No
≥ 2000	< 5000	Yes	No	Yes
< 2000	< 5000	No	No	Yes

Important Notes :

- (a) Ventilation requirement stated paragraph (7) is a pre-requisite requirement to attain Green Platinum rating.
- (b) The stipulated energy savings and Design System Efficiency (DSE) of cooling system stated in paragraph (2) and (3) are pre-requisites to attain Green Mark Gold^{Plus} and Platinum rating.
- (c) Detailed calculations to be provided to justify the savings in energy consumption from the use of salient energy efficient features /equipment. Energy savings will be based on the energy efficiency measures and improvements over the reference model established for similar building types. The reference ACMV system will be of the same type as the proposed system. The baseline used for the equipment will be in accordance with the minimum efficiency requirement stipulated in SS 530. For VRF system, the baseline COP of 3.37 shall be adopted. The stipulated energy savings stated in paragraph (2) are pre-requisites to attain Green Mark Gold^{Plus} and Platinum rating.
- (d) Other pre-requisite stated paragraph (1), (4), (5), (6), (8) and (9) are applicable where relevant.

BCA Green Mark for Non-Residential Building Criteria (Version NRB/4.1)

Part 1 – Energy Efficiency	Green Mark Points								
(A) Applicable to Air-Conditioned Building Areas (with an aggregate air-conditioned areas > 500 m²)									
<p><u>NRB 1-1 Thermal Performance of Building Envelope – Envelope Thermal Transfer Value (ETTV)</u></p> <p>Enhance the overall thermal performance of building envelope to minimise heat gain thus reducing the overall cooling load requirement.</p> <p><u>Baseline</u> : Maximum Permissible ETTV = 50 W/m²</p> <p><u>Prerequisite Requirement</u> : Green Mark Gold^{Plus} – ETTV of 42 W/m² or less Green Mark Platinum – ETTV of 40 W/m² or less</p>	<p>1.2 points for every reduction of 1 W/m² in ETTV from the baseline</p> <p>Points scored = 1.2 x (50 - ETTV) where ETTV ≤ 50 W/m²</p> <p>(Up to 12 points)</p>								
<p><u>NRB 1-2 Air-Conditioning System</u></p> <p>Encourage the use of better energy efficient air-conditioned equipment to minimise energy consumption.</p> <p>(a) Water-Cooled Chilled-Water Plant :</p> <ul style="list-style-type: none"> • Water-Cooled Chiller • Chilled-Water Pump • Condenser Water Pump • Cooling Tower <table border="1" data-bbox="172 1099 799 1339"> <thead> <tr> <th rowspan="2" style="text-align: left;">Baseline</th> <th colspan="2" style="text-align: center;">Peak Building Cooling Load</th> </tr> <tr> <th style="text-align: center;">≥ 500 RT</th> <th style="text-align: center;">< 500 RT</th> </tr> </thead> <tbody> <tr> <td style="text-align: left;"><u>Prerequisite Requirements</u> Minimum Design System Efficiency (DSE) for central chilled-water plant</td> <td style="text-align: center;">0.70 kW/RT</td> <td style="text-align: center;">0.80 kW/RT</td> </tr> </tbody> </table> <p><u>Prerequisite Requirements for Higher Green Mark Rating</u> : Green Mark Gold^{Plus} & Platinum : Minimum Design System Efficiency (DSE) of 0.65 kW/RT for peak building cooling load ≥ 500 RT and 0.7 kW/RT for peak building cooling load < 500 RT</p> <p>(b) Air Cooled Chilled-Water Plant / Unitary Air-Conditioners</p> <p style="padding-left: 20px;">Air Cooled Chilled-Water Plant :</p> <ul style="list-style-type: none"> • Air-Cooled Chiller • Chilled-Water Pump <p style="padding-left: 20px;">Unitary Air-Conditioners :</p> <ul style="list-style-type: none"> • Variable Refrigerant Flow (VRF) system • Single-Split Unit • Multi-Split Unit 	Baseline	Peak Building Cooling Load		≥ 500 RT	< 500 RT	<u>Prerequisite Requirements</u> Minimum Design System Efficiency (DSE) for central chilled-water plant	0.70 kW/RT	0.80 kW/RT	<p><u>(a) Water-Cooled Chilled-Water Plant</u></p> <div style="border: 1px solid black; padding: 5px; text-align: center; margin: 10px 0;">Peak building cooling load ≥ 500 RT</div> <p>15 points for meeting the prescribed chilled-water plant efficiency of 0.70 kW/RT</p> <p>0.25 point for every percentage improvement in the chilled-water plant efficiency over the baseline</p> <p>Points scored = 0.25 x (% improvement)</p> <div style="border: 1px solid black; padding: 5px; text-align: center; margin: 10px 0;">Peak building cooling load < 500 RT</div> <p>12 points for meeting the prescribed chilled-water plant efficiency of 0.80 kW/RT</p> <p>0.45 point for every percentage improvement in the chilled-water plant efficiency over the baseline</p> <p>Points scored = 0.45 x (% improvement) (Up to 20 points)</p> <p><u>(b) Air Cooled Chilled-Water Plant/ Unitary Air-Conditioners</u></p> <div style="border: 1px solid black; padding: 5px; text-align: center; margin: 10px 0;">Peak building cooling load ≥ 500 RT</div> <p>12 points for meeting the prescribed air-conditioning system efficiency of 0.80 kW/RT</p> <p>1.3 points for every percentage improvement in the air-conditioning system efficiency over the baseline</p> <p>Points scored = 1.3 x (% improvement)</p>
Baseline		Peak Building Cooling Load							
	≥ 500 RT	< 500 RT							
<u>Prerequisite Requirements</u> Minimum Design System Efficiency (DSE) for central chilled-water plant	0.70 kW/RT	0.80 kW/RT							

Part 1 – Energy Efficiency	Green Mark Points																																				
(A) Applicable to Air-Conditioned Building Areas (with an aggregate air-conditioned areas > 500 m²)																																					
<p>(b) Air Cooled Chilled-Water Plant / Unitary Air-Conditioners – <i>Cont'd</i></p> <table border="1" data-bbox="169 297 805 562"> <thead> <tr> <th rowspan="2">Baseline</th> <th colspan="2">Peak Building Cooling Load</th> </tr> <tr> <th>≥ 500 RT</th> <th>< 500 RT</th> </tr> </thead> <tbody> <tr> <td><u>Prerequisite Requirements</u> Minimum Design System Efficiency (DSE) for air cooled chilled-water plant or unitary conditioners</td> <td>0.80 kW/RT</td> <td>0.90 kW/RT</td> </tr> </tbody> </table> <p><u>Prerequisite Requirements for Higher Green Mark Rating :</u> Green Mark Gold^{Plus} : Minimum Design System Efficiency (DSE) of 0.85kW/RT for peak building cooling load < 500 RT Green Mark Platinum: Minimum DSE of 0.78kW/RT for peak building cooling load < 500 RT</p> <p>Note (1) : Where there is a combination of central chilled water plant with unitary conditioners, the points scored will only be based on the air-conditioning system with a larger aggregate capacity.</p> <p>(c) Air Distribution System :</p> <ul style="list-style-type: none"> • Air Handling Units (AHUs) • Fan Coil Units (FCUs) <p><u>Option 1 – Fan System Motor Nameplate Power</u> <u>Baseline :</u> SS553:2009 Table 2 – Fan power limitation and as prescribed below :</p> <table border="1" data-bbox="169 1086 815 1400"> <thead> <tr> <th rowspan="2">Baseline Air Distribution System Type</th> <th colspan="2">Allowable Motor Nameplate Power</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>AHUs/FCUs ≥ 4kW (Constant Volume)</td> <td>1.7</td> <td>0.47</td> </tr> <tr> <td>AHUs ≥ 4kW (Variable Volume)</td> <td>2.4</td> <td>0.67</td> </tr> <tr> <td>Fan systems with nameplate motor power < 4 kW</td> <td colspan="2">No baseline</td> </tr> </tbody> </table> <p><u>Option 2 – Fan System Input Power</u> <u>Baseline :</u> ASHRAE 90.1:2010 Clause 6.5.3.1 and as prescribed below :</p> <table border="1" data-bbox="169 1527 815 1854"> <thead> <tr> <th rowspan="2">Baseline Air Distribution System Type</th> <th colspan="2">Allowable Fan System Input Power*</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>AHUs/FCUs ≥ 4kW (Constant Volume)</td> <td>1.5</td> <td>0.42</td> </tr> <tr> <td>AHUs ≥ 4kW (Variable Volume)</td> <td>2.1</td> <td>0.58</td> </tr> <tr> <td>Fan systems with nameplate motor power < 4 kW</td> <td>0.6</td> <td>0.17</td> </tr> </tbody> </table> <p>* Applicable pressure drop adjustments can be considered based on ASHRAE 90.1 Table 6.5.3.1.1B and are subject to BCA's evaluation</p> <p>Note (2) : For buildings with cooling provision from a licensed District Cooling System (DCS) supplier where the plant efficiency data is not available, the point scored for NRB 1-2(a) and (b) will be pro-rated based on the air distribution system efficiency under NRB 1-2(c).</p>	Baseline	Peak Building Cooling Load		≥ 500 RT	< 500 RT	<u>Prerequisite Requirements</u> Minimum Design System Efficiency (DSE) for air cooled chilled-water plant or unitary conditioners	0.80 kW/RT	0.90 kW/RT	Baseline Air Distribution System Type	Allowable Motor Nameplate Power		(kW/m ³ /s)	(W/CMH)	AHUs/FCUs ≥ 4kW (Constant Volume)	1.7	0.47	AHUs ≥ 4kW (Variable Volume)	2.4	0.67	Fan systems with nameplate motor power < 4 kW	No baseline		Baseline Air Distribution System Type	Allowable Fan System Input Power*		(kW/m ³ /s)	(W/CMH)	AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42	AHUs ≥ 4kW (Variable Volume)	2.1	0.58	Fan systems with nameplate motor power < 4 kW	0.6	0.17	<div style="border: 1px solid black; padding: 5px; margin-bottom: 20px;"> <p align="center">Peak building cooling load < 500 RT</p> </div> <p>10 points for meeting the prescribed air-conditioning system efficiency of 0.90 kW/RT</p> <p>0.6 point for every percentage improvement in the air-conditioning system efficiency over the baseline</p> <p>Points scored = 0.6 x (% improvement)</p> <p align="center">(Up to 20 points)</p> <p><u>(c) Air Distribution System</u> 0.2 point for every percentage improvement in the air distribution system efficiency over the baseline</p> <p>Points scored = 0.2 x (% improvement)</p> <p align="center">(Up to 6 points)</p>
Baseline		Peak Building Cooling Load																																			
	≥ 500 RT	< 500 RT																																			
<u>Prerequisite Requirements</u> Minimum Design System Efficiency (DSE) for air cooled chilled-water plant or unitary conditioners	0.80 kW/RT	0.90 kW/RT																																			
Baseline Air Distribution System Type	Allowable Motor Nameplate Power																																				
	(kW/m ³ /s)	(W/CMH)																																			
AHUs/FCUs ≥ 4kW (Constant Volume)	1.7	0.47																																			
AHUs ≥ 4kW (Variable Volume)	2.4	0.67																																			
Fan systems with nameplate motor power < 4 kW	No baseline																																				
Baseline Air Distribution System Type	Allowable Fan System Input Power*																																				
	(kW/m ³ /s)	(W/CMH)																																			
AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42																																			
AHUs ≥ 4kW (Variable Volume)	2.1	0.58																																			
Fan systems with nameplate motor power < 4 kW	0.6	0.17																																			

Part 1 – Energy Efficiency	Green Mark Points												
(B) Applicable to Non Air-Conditioned Building Areas (with an aggregate non air-conditioned areas > 10 % of total floor area excluding carparks and common areas)													
<p><u>NRB 1-3 Building Envelope – Design / Thermal Parameters</u></p> <p>Enhance the overall thermal performance of building envelope to minimise heat gain that would improve indoor thermal comfort and encourage natural ventilation or mechanical ventilation.</p> <p>(a) Minimum direct west facing façade through building design orientation.</p> <p>Note (3) : Orientation of façade that falls within the range of 22.5° N of W and 22.5° S of W will be defined as west facing facade. Core walls for lifts or staircases and toilets that are located within this range are exempted in computation.</p> <p>(b)(i) Minimum west facing window openings.</p> <p>(b)(ii) Effective sunshading provision for windows on the west façade with minimum shading of 30%.</p> <p>(c) Better thermal transmittance (U-value) of external west facing walls.</p> <p>The U-value of external west facing walls should be equal or less than 2 W/m²K.</p> <p>(d) Better thermal transmittance (U-value) of roof.</p> <p><u>Baseline</u>: U-value for roof stated below depending on the weight range of roof structure:</p> <table border="1" data-bbox="220 1639 730 1841"> <thead> <tr> <th>Weight Group</th> <th>Weight range (kg/m²)</th> <th>Maximum Thermal Transmittance (W/m²K)</th> </tr> </thead> <tbody> <tr> <td>Light</td> <td>Under 50</td> <td>0.8</td> </tr> <tr> <td>Medium</td> <td>50 to 230</td> <td>1.1</td> </tr> <tr> <td>Heavy</td> <td>Over 230</td> <td>1.5</td> </tr> </tbody> </table>	Weight Group	Weight range (kg/m ²)	Maximum Thermal Transmittance (W/m ² K)	Light	Under 50	0.8	Medium	50 to 230	1.1	Heavy	Over 230	1.5	<p>Points scored = $15 - 0.3 \times (\% \text{ of west facing facade areas over total facade areas})$</p> <p>(Up to 15 points)</p> <p>Where there is no west facing façade, the total points scored for this item will be <u>30 points</u>; the NRB 1-3 b(i), b(ii) and (c) as listed below will not be applicable.</p> <p>Points scored = $10 - 0.1 \times (\% \text{ of west facing window areas over total west facing facade areas})$</p> <p>Points scored = $0.1 \times (\% \text{ of west facing window areas with sunshading devices over total west facing facade areas})$</p> <p>(Up to 10 points for NRB 1-3 b(i) & b(ii))</p> <p>Points scored = $0.05 \times (\% \text{ of the external west facing walls areas with U value of } 2 \text{ W/m}^2\text{K or less over total west facing facades areas})$</p> <p>(up to 5 points)</p> <p>1 point for every 0.1 W/m²K reduction from the baseline roof U-value</p> <p>(Up to 5 points)</p>
Weight Group	Weight range (kg/m ²)	Maximum Thermal Transmittance (W/m ² K)											
Light	Under 50	0.8											
Medium	50 to 230	1.1											
Heavy	Over 230	1.5											
<p><i>Exception : For existing buildings, NRB 1-3(a) may be excluded in computation, the total score obtained under NRB 1-3 (b), (c) and (d) will be prorated accordingly.</i></p>													

Part 1 – Energy Efficiency	Green Mark Points																						
(B) Applicable to Non Air-Conditioned Building Areas (with an aggregate non air-conditioned areas > 10 % of total floor area excluding carparks and common areas)																							
<p><u>NRB 1-4 Natural Ventilation / Mechanical Ventilation</u></p> <p>(a) <u>Natural Ventilation</u></p> <p>Encourage building design that facilitates good natural ventilation.</p> <p>(i) Proper design of building layout that utilises prevailing wind conditions to achieve adequate cross ventilation.</p> <p>(ii) Use of ventilation simulation modeling and analysis or wind tunnel testing to identify the most effective building design and layout to ensure good natural ventilation.</p> <p><i>Prerequisite Requirement :</i> <i>Green Mark Platinum : Ventilation simulation modeling and analysis are to be carried out to ensure good natural ventilation with minimum weighted average wind velocity of 0.6 m/s within the functional spaces or units.</i></p> <p>(b) <u>Mechanical Ventilation</u></p> <p>Encourage energy efficient mechanical ventilation system design as the preferred ventilation mode to minimise air-conditioned spaces.</p> <p><u>Option 1 – Fan System Motor Nameplate Power</u></p> <p><u>Baseline</u> : SS553:2009 Table 8 – Fan power limitation and as prescribed below :</p> <table border="1" data-bbox="169 1120 813 1370"> <thead> <tr> <th rowspan="2">Baseline Air Distribution System Type</th> <th colspan="2">Allowable Motor Nameplate Power</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>AHUs/FCUs ≥ 4kW (Constant Volume)</td> <td>1.7</td> <td>0.47</td> </tr> <tr> <td>Fan systems with nameplate motor power < 4 kW</td> <td colspan="2">No baseline</td> </tr> </tbody> </table> <p><u>Option 2 – Fan System Input Power</u></p> <p><u>Baseline</u> : ASHRAE 90.1 : 2010 Clause 6.5.3.1 and as prescribed below :</p> <table border="1" data-bbox="169 1505 813 1827"> <thead> <tr> <th rowspan="2">Baseline Air Distribution System Type</th> <th colspan="2">Allowable Fan System Input Power *</th> </tr> <tr> <th>(kW/m³/s)</th> <th>(W/CMH)</th> </tr> </thead> <tbody> <tr> <td>AHUs/FCUs ≥ 4kW (Constant Volume)</td> <td>1.5</td> <td>0.42</td> </tr> <tr> <td>Fan systems with nameplate motor power < 4 kW</td> <td>0.6</td> <td>0.17</td> </tr> </tbody> </table> <p>* Applicable pressure drop adjustments can be considered based on ASHRAE 90.1 Table 6.5.3.1.1B and are subject to BCA's evaluation</p> <p>Note (4) : Where there is a combination of naturally ventilated and mechanical ventilated spaces, points scored will be based on the predominant ventilation modes of normally occupied spaces.</p>	Baseline Air Distribution System Type	Allowable Motor Nameplate Power		(kW/m ³ /s)	(W/CMH)	AHUs/FCUs ≥ 4kW (Constant Volume)	1.7	0.47	Fan systems with nameplate motor power < 4 kW	No baseline		Baseline Air Distribution System Type	Allowable Fan System Input Power *		(kW/m ³ /s)	(W/CMH)	AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42	Fan systems with nameplate motor power < 4 kW	0.6	0.17	<p>1 point for every 10% of units/rooms with window openings facing north and south directions Points scored = 1 x (% of units/10) (Up to 10 points)</p> <p>5 points Additional 5 points if the recommendations are implemented and meet the air-flow requirement (Up to 10 points)</p> <p>0.6 point for every percentage improvement in the mechanical ventilation system efficiency over the baseline Points scored = 0.6 x (% improvement) (Up to 15 points)</p>
Baseline Air Distribution System Type		Allowable Motor Nameplate Power																					
	(kW/m ³ /s)	(W/CMH)																					
AHUs/FCUs ≥ 4kW (Constant Volume)	1.7	0.47																					
Fan systems with nameplate motor power < 4 kW	No baseline																						
Baseline Air Distribution System Type	Allowable Fan System Input Power *																						
	(kW/m ³ /s)	(W/CMH)																					
AHUs/FCUs ≥ 4kW (Constant Volume)	1.5	0.42																					
Fan systems with nameplate motor power < 4 kW	0.6	0.17																					
Sub-Total (B) :	Sum of Green Mark Points obtained from NRB 1-3 to 1-4																						

Part 1 - Energy Efficiency	Green Mark Points								
(C) General									
<p><u>NRB 1-5 Daylighting</u></p> <p>Encourage design that optimises the use of effective daylighting to reduce energy use for artificial lighting.</p> <p>(a) Use of daylighting and glare simulation analysis to verify the adequacy of ambient lighting levels in meeting the illuminance level and Unified Glare Rating (UGR) stated in SS 531:Part 1:2006 – Code of Practice for Lighting of Work Places.</p> <p>(b) Daylighting for the following common areas:</p> <ul style="list-style-type: none"> (i) Toilets (ii) Staircases (iii) Corridors (iv) Lift Lobbies (v) Atriums (vi) Carparks <p>Note (5) : All daylit areas must be integrated with automatic electric lighting control system.</p>	<p>Extent of coverage: At least 75% of the units with daylighting provisions meet the minimum illuminance level and are within the acceptable glare exposure.</p> <p>Points scored based on the extent of perimeter daylight zones</p> <table border="1" data-bbox="898 481 1439 667"> <thead> <tr> <th>Distance from the Façade Perimeters (m)</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>≥ 3.0</td> <td>1</td> </tr> <tr> <td>4.0 – 5.0</td> <td>2</td> </tr> <tr> <td>> 5.0</td> <td>3</td> </tr> </tbody> </table> <p>(Up to 3 points)</p> <p>Extent of Coverage : At least 80 % of each applicable area</p> <p>0.5 point each (Up to 3 points)</p>	Distance from the Façade Perimeters (m)	Points Allocation	≥ 3.0	1	4.0 – 5.0	2	> 5.0	3
Distance from the Façade Perimeters (m)	Points Allocation								
≥ 3.0	1								
4.0 – 5.0	2								
> 5.0	3								
<p><u>NRB 1-6 Artificial Lighting</u></p> <p>Encourage the use of energy efficient lighting to minimise energy consumption from lighting usage while maintaining proper lighting level.</p> <p><u>Baseline</u> : Maximum lighting power budget stated in SS 530</p>	<p>0.3 point for every percentage improvement in lighting power budget</p> <p>Points scored = 0.3 x (% improvement) (Including tenant lighting provision) (Up to 12 points)</p> <p>(Excluding tenant lighting provision) (Up to 5 points)</p>								
<p><u>NRB 1-7 Ventilation in Carparks</u></p> <p>Encourage the use of energy efficient design and control of ventilation systems in carparks.</p> <p>(a) Carparks are designed with natural ventilation.</p> <p>(b) CO sensors are used to regulate the demand for mechanical ventilation (MV).</p> <p>Note (6) : Where there is a combination of different ventilation mode adopted for carpark design, the points obtained under NRB 1-7 will be prorated accordingly.</p>	<p>Naturally ventilated carparks – 4 points</p> <p>Points scored based on the mode of mechanical ventilation provided</p> <p>Fume extract – 2.5 points</p> <p>MV with or without supply - 2 points (Up to 4 points)</p>								

Part 1 - Energy Efficiency	Green Mark Points
(C) General	
<p><u>NRB 1-8 Ventilation in Common Areas</u></p> <p>Encourage the use of energy efficient design and control of ventilation systems in the following common areas :</p> <p>(a) Toilets (b) Staircases (c) Corridors (d) Lift lobbies (e) Atrium</p>	<p>Extent of Coverage : At least 90 % of each applicable area</p> <p>Points scored based on the mode of ventilation provided in applicable areas</p> <p>Natural ventilation – 1.5 points for each area</p> <p>Mechanical ventilation – 0.5 point for each area</p> <p>(Up to 5 points)</p>
<p><u>NRB 1-9 Lifts and Escalators</u></p> <p>Encourage the use of energy efficient lifts and escalators.</p> <p>Lifts and/or escalators with AC variable voltage and variable frequency (VVVF) motor drive and sleep mode features.</p>	<p>Extent of Coverage : All lifts and escalators</p> <p>Lifts – 1 point</p> <p>Escalators – 1 point</p>
<p><u>NRB 1-10 Energy Efficient Practices & Features</u></p> <p>Encourage the use of energy efficient practices and features that are innovative and/or have positive environmental impact.</p> <p>(a) Computation of energy consumption based on design load in the form of energy efficiency index (EEI).</p> <p>(b) Use of vertical greenery system on east and west façade to reduce heat gain through building envelope</p> <p>(c) Use of energy efficient equipment or product that are certified by approved local certification body</p> <p>(d) Use of energy efficient features.</p> <p>Examples:</p> <ul style="list-style-type: none"> ■ Heat recovery system ■ Sun pipes ■ Regenerative lifts ■ Light shelves ■ Photocell sensors to maximise the use of daylighting 	<p>1 point</p> <p>1 point for high impact 0.5 point for low impact</p> <p>Extent of Coverage : 90% of the applicable equipment type or product</p> <p>0.5 point for each eligible certified equipment or products</p> <p>(Up to 2 points)</p> <p>3 points for every 1% energy saving over total building energy consumption</p> <p>(Up to 8 points)</p>

Part 1 – Energy Efficiency	Green Mark Points											
(C) General												
<p><u>NRB 1-11 Renewable Energy</u></p> <p>Encourage the application of renewable energy sources in buildings.</p>	<p>Point scored based on the expected energy efficiency index (EEI) and % replacement of electricity by renewable energy source</p> <table border="1" data-bbox="837 365 1444 734"> <thead> <tr> <th data-bbox="837 365 1034 607" rowspan="2">Expected Energy Efficiency Index (EEI)</th> <th colspan="2" data-bbox="1034 365 1444 483">Every 1% replacement of electricity (based on total building electricity consumption) by renewable energy source</th> </tr> <tr> <th data-bbox="1034 483 1241 607">Include tenant's usage</th> <th data-bbox="1241 483 1444 607">Exclude tenant's usage</th> </tr> </thead> <tbody> <tr> <td data-bbox="837 607 1034 672">≥ 30 kWh/m²/yr</td> <td data-bbox="1034 607 1241 672">5 points</td> <td data-bbox="1241 607 1444 672">3 points</td> </tr> <tr> <td data-bbox="837 672 1034 734">< 30 kWh/m²/yr</td> <td data-bbox="1034 672 1241 734">3 points</td> <td data-bbox="1241 672 1444 734">1.5 points</td> </tr> </tbody> </table> <p>(Up to 20 Points)</p> <p><i>Condition : The points scored for renewable energy provision shall not result in a double grade jump in the GM rating (i.e. from GM Certified to Gold^{Plus} or Gold to Platinum rating).</i></p>	Expected Energy Efficiency Index (EEI)	Every 1% replacement of electricity (based on total building electricity consumption) by renewable energy source		Include tenant's usage	Exclude tenant's usage	≥ 30 kWh/m ² /yr	5 points	3 points	< 30 kWh/m ² /yr	3 points	1.5 points
Expected Energy Efficiency Index (EEI)	Every 1% replacement of electricity (based on total building electricity consumption) by renewable energy source											
	Include tenant's usage	Exclude tenant's usage										
≥ 30 kWh/m ² /yr	5 points	3 points										
< 30 kWh/m ² /yr	3 points	1.5 points										
Sub-Total (C) :	Sum of Green Mark Points obtained from NRB 1-5 to 1-11											
PART 1 – ENERGY EFFICIENCY CATEGORY SCORE :	$\text{Sub-Total (A)} \times \frac{\text{Air-Conditioned Building Floor Area}}{\text{Total Floor Area}} + \text{Sub-Total (B)} \times \frac{\text{Non Air-Conditioned Building Floor Area}}{\text{Total Floor Area}} + \text{Sub-Total (C)}$ <p>where Sub-Total (A) = Sum of Green Mark Points obtained under Section (A) NRB 1-1 to 1-2 Sub-Total (B) = Sum of Green Mark Points obtained under Section (B) NRB 1-3 to 1-4 Sub-Total (C) = Sum of Green Mark Points obtained under Section (C) NRB 1-5 to 1-11</p>											

Part 2 – Water Efficiency	Green Mark Points							
<p><u>NRB 2-1 Water Efficient Fittings</u> Encourage the use of water efficient fittings covered under the Water Efficiency Labelling Scheme (WELS).</p> <p>(a) Basin taps and mixers (b) Flushing cistern (c) Shower taps, mixers or showerheads (d) Sink/Bib taps and mixers (e) Urinals and urinal flush valve</p>	<p>Rating based on Water Efficiency Labelling Scheme (WELS)</p> <table border="1" data-bbox="821 358 1141 571"> <tr> <td data-bbox="821 358 981 421">Very Good</td> <td data-bbox="981 358 1141 421">Excellent</td> </tr> <tr> <td colspan="2" data-bbox="821 421 1141 470">Weightage</td> </tr> <tr> <td data-bbox="821 470 981 571">8</td> <td data-bbox="981 470 1141 571">10</td> </tr> </table>	Very Good	Excellent	Weightage		8	10	<p>Points scored based on the number and water efficiency rating of the fitting type used</p> <p>(Up to 10 points)</p>
Very Good	Excellent							
Weightage								
8	10							
<p><u>NRB 2-2 Water Usage and Leak Detection</u> Promote the use of sub-metering and leak detection system for better control and monitoring.</p> <p>(a) Provision of private meters to monitor the major water usage such as irrigation, cooling tower and tenants' usage.</p> <p>(b) Linking all private meters to the Building Management System (BMS) for leak detection.</p>		<p>1 point</p> <p>1 point</p>						
<p><u>NRB 2-3 Irrigation System and Landscaping</u> Provision of suitable systems that utilise rainwater or recycled water and use of plants that require minimal irrigation to reduce potable water consumption.</p> <p>(a) Use of non potable water including rainwater for landscape irrigation.</p> <p>(b) Use of automatic water efficient irrigation system with rain sensor.</p> <p>(c) Use of drought tolerant plants that require minimal irrigation.</p>		<p>1 point</p> <p>Extent of Coverage : At least 50% of the landscape areas are served by the system 1 point</p> <p>Extent of Coverage : At least 80% of the landscape areas 1 point</p>						
<p><u>NRB 2-4 Water Consumption of Cooling Tower</u> Reduce potable water use for cooling purpose.</p> <p>(a) Use of cooling tower water treatment system that can achieve 7 or better cycles of concentration at acceptable water quality.</p> <p>(b) Use of NEWater or on-site recycled water from approved sources.</p>		<p>1 point</p> <p>1 point</p>						
<p>PART 2 – WATER EFFICIENCY CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from NRB 2-1 to 2-4</p>							

Part 3 – Environmental Protection	Green Mark Points																								
<p>NRB 3-1 Sustainable Construction</p> <p>Encourage recycling and the adoption of building designs, construction practices and materials that are environmentally friendly and sustainable</p> <p>(a) Use of Sustainable and Recycled Materials</p> <p>(i) Green Cements with approved industrial by-product (such as Ground Granulated Blastfurnace Slag (GGBS), silica fume, fly ash) to replace Ordinary Portland Cement (OPC) by at least 10% by mass for superstructural works.</p> <p>(ii) Recycled Concrete Aggregates (RCA) and Washed Copper Slag (WCS) from approved sources to replace coarse and fine aggregates for concrete production of main building elements.</p> <p>Note (7) : For structural building elements, the use of RCA and WCS shall be limited to maximum 10% replacement by mass of coarse/fine aggregates respectively or as approved by the relevant authorities.</p> <p>(b) Concrete Usage Index (CUI)</p> <p>Encourage designs with efficient use of concrete for building components.</p> <p><u>Prerequisite Requirement:</u> Minimum points to be scored under this criterion: Green Mark Gold^{plus} ≥ 3 points Green Mark Platinum ≥ 5 points</p>	<p>1 point</p> <p>1 point for every incremental of 0.5 times (0.5x) of the usage requirement (Up to 2x)</p> <table border="1" data-bbox="842 667 1449 943"> <thead> <tr> <th>Quantity of RCA /WCS (tons)</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>≥ 0.5 x usage requirement</td> <td>1</td> </tr> <tr> <td>≥ 1.0 x usage requirement</td> <td>2</td> </tr> <tr> <td>≥ 1.5 x usage requirement</td> <td>3</td> </tr> <tr> <td>≥ 2.0 x usage requirement</td> <td>4</td> </tr> </tbody> </table> <p>where usage requirement = 0.03 x (GFA in m²) (Up to 5 points for NRB 3-1(a)(i) and (a)(ii))</p> <table border="1" data-bbox="850 1205 1433 1496"> <thead> <tr> <th>Project CUI (m³/m²)</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>≤ 0.70</td> <td>1</td> </tr> <tr> <td>≤ 0.60</td> <td>2</td> </tr> <tr> <td>≤ 0.50</td> <td>3</td> </tr> <tr> <td>≤ 0.40</td> <td>4</td> </tr> <tr> <td>≤ 0.35</td> <td>5</td> </tr> </tbody> </table>			Quantity of RCA /WCS (tons)	Points Allocation	≥ 0.5 x usage requirement	1	≥ 1.0 x usage requirement	2	≥ 1.5 x usage requirement	3	≥ 2.0 x usage requirement	4	Project CUI (m ³ /m ²)	Points Allocation	≤ 0.70	1	≤ 0.60	2	≤ 0.50	3	≤ 0.40	4	≤ 0.35	5
Quantity of RCA /WCS (tons)	Points Allocation																								
≥ 0.5 x usage requirement	1																								
≥ 1.0 x usage requirement	2																								
≥ 1.5 x usage requirement	3																								
≥ 2.0 x usage requirement	4																								
Project CUI (m ³ /m ²)	Points Allocation																								
≤ 0.70	1																								
≤ 0.60	2																								
≤ 0.50	3																								
≤ 0.40	4																								
≤ 0.35	5																								
<p>NRB 3-2 Sustainable Products</p> <p>Promote use of environmentally friendly products that are certified by approved local certification body and are applicable to non-structural and architectural related building components.</p> <p><u>Prerequisite Requirement:</u> Minimum score under this criterion: Green Mark Gold^{plus} ≥ 3 points Green Mark Platinum ≥ 4 points</p>	<table border="1"> <thead> <tr> <th colspan="3">Weightage based on the extent of environmental friendliness of products</th> </tr> <tr> <th>Good</th> <th>Very Good</th> <th>Excellent</th> </tr> </thead> <tbody> <tr> <td>0.5</td> <td>1.5</td> <td>2</td> </tr> </tbody> </table>		Weightage based on the extent of environmental friendliness of products			Good	Very Good	Excellent	0.5	1.5	2	<p>Points scored based on the weightage and the extent of coverage & impact</p> <p>1 point for high impact item 0.5 point for low impact item (Up to 8 points)</p>													
Weightage based on the extent of environmental friendliness of products																									
Good	Very Good	Excellent																							
0.5	1.5	2																							

Part 3 – Environmental Protection	Green Mark Points														
<p><u>NRB 3-3 Greenery Provision</u></p> <p>Encourage greater use of greenery, restoration of trees to reduce heat island effect.</p> <p>(a) Green Plot Ratio (GnPR) is calculated by considering the 3D volume covered by plants using the prescribed Leaf Area Index (LAI).</p> <p>(b) Restoration, conservation or relocation of existing trees on site.</p> <p>(c) Use of compost recycled from horticulture waste.</p>	<table border="1" data-bbox="868 203 1402 465"> <thead> <tr> <th>GnPR</th> <th>Points Allocation</th> </tr> </thead> <tbody> <tr> <td>0.5 to < 1.0</td> <td>1</td> </tr> <tr> <td>1.0 to < 1.5</td> <td>2</td> </tr> <tr> <td>1.5 to < 3.0</td> <td>3</td> </tr> <tr> <td>3.0 to < 3.5</td> <td>4</td> </tr> <tr> <td>3.5 to < 4.0</td> <td>5</td> </tr> <tr> <td>≥ 4.0</td> <td>6</td> </tr> </tbody> </table> <p>1 point</p> <p>1 point</p>	GnPR	Points Allocation	0.5 to < 1.0	1	1.0 to < 1.5	2	1.5 to < 3.0	3	3.0 to < 3.5	4	3.5 to < 4.0	5	≥ 4.0	6
GnPR	Points Allocation														
0.5 to < 1.0	1														
1.0 to < 1.5	2														
1.5 to < 3.0	3														
3.0 to < 3.5	4														
3.5 to < 4.0	5														
≥ 4.0	6														
<p><u>NRB 3-4 Environmental Management Practice</u></p> <p>Encourage the adoption of environmental friendly practices during construction and building operation.</p> <p>(a) Implement effective environmental friendly programmes including monitoring and setting targets to minimise energy use, water use and construction waste.</p> <p>(b) Main builder that has good track records in the adoption of sustainable, environmentally friendly and considerate practices during construction such as the Green and Gracious Builder Award.</p> <p>(c) Building quality assessed under the Construction Quality Assessment System (CONQUAS).</p> <p>(d) Developer, main builder, M & E consultant and architect that are ISO 14000 certified.</p> <p>(e) Project team comprises Certified Green Mark Manager (GMM), Green Mark Facilities Manager (GMFM) and Green Mark Professional (GMP).</p> <p>(f) Provision of building users' guide that should include details of the environmental friendly facilities and features within the building and their functionalities in achieving the intended environmental performance during building operation.</p> <p>(g) Provision of facilities or recycling bins for collection and storage of different recyclable waste such as paper, glass, plastic food waste etc.</p>	<p>1 point</p> <p>1 point</p> <p>1 point</p> <p>0.25 point for each firm (Up to 1 point)</p> <p>0.5 point for certified GMM 0.5 point for certified GMFM 1 point for certified GMP (Up to 1 point)</p> <p>1 point</p> <p>1 point</p>														

Part 3 – Environmental Protection	Green Mark Points
<p><u>NRB 3-5 Green Transport</u></p> <p>Promote environmental friendly transport options and facilities to reduce pollution from individual car use.</p> <p>(a) Good access to nearest MRT/LRT or bus stops.</p> <p>(b) Provision of covered walkway to facilitate connectivity and the use of public transport.</p> <p>(c) Provision of electric vehicle charging stations and priority parking lots within the development.</p> <p>(d) Provision of sheltered bicycle parking lots with adequate shower and changing facilities.</p>	<p>1 point</p> <p>1 point</p> <p>Extent of Coverage : Minimum one(1) electric vehicle charging station and priority parking lot for every 100 carpark lots (<i>Cap at 5</i>)</p> <p>1 point</p> <p>Extent of Coverage : Minimum ten (10) bicycle parking lots (<i>Cap at 50</i>)</p> <p>Points scored based on the number of bicycle parking lots provided (<i>with adequate shower and changing facilities</i>)</p> <p>1 point if the number provided $\geq 3\% \times \text{Gross Floor Area (GFA)}/10$</p> <p>0.5 point if the number provided $\geq 1.5\% \times \text{Gross Floor Area (GFA)}/10$</p>
<p><u>NRB 3-6 Refrigerants</u></p> <p>Reduce the potential damage to the ozone layer and the increase in global warming caused by the release of ozone depleting substances and greenhouse gases.</p> <p>(a) Refrigerants with ozone depletion potential (ODP) of zero or with global warming potential (GWP) of less than 100.</p> <p>(b) Use of refrigerant leak detection system in critical areas of plant rooms containing chillers and other equipments with refrigerants.</p>	<p>1 point</p> <p>1 point</p>
<p><u>NRB 3-7 Stormwater Management</u></p> <p>Encourage treatment of stormwater run-off before discharge to the public drains.</p> <p>Provision of infiltration or design features as recommended in PUB's ABC Waters Design Guidelines :</p> <ul style="list-style-type: none"> ▪ Bioretention swales/ other bioretention systems ▪ Rain gardens ▪ Constructed wetlands ▪ Cleansing biotopes ▪ Retention ponds 	<p>Points scored based on the extent of stormwater treatment.</p> <p>3 points for treatment of run-off from more than 35% of total site area or paved area</p> <p>2 points for treatment of run-off from 10% to 35% of total site area</p> <p>1 point for treatment of run-off from up to 10% of total site area</p>
<p>PART 3 – ENVIRONMENTAL PROTECTION CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from NRB 3-1 to 3-7</p>

Part 4 – Indoor Environmental Quality	Green Mark Points
<p><u>NRB 4-1 Thermal Comfort</u></p> <p>Air-conditioning system is designed to allow for cooling load variation due to fluctuations in ambient air temperature and to maintain consistent indoor conditions for thermal comfort.</p> <p>Indoor operative temperature between 24 °C to 26 °C Relative humidity < 65%</p>	<p>1 point</p>
<p><u>NRB 4-2 Noise Level</u></p> <p>Occupied spaces in buildings are designed with good ambient sound levels as recommended in SS 553 Table 4 – Recommended ambient sound level.</p>	<p>1 point</p>
<p><u>NRB 4-3 Indoor Air Pollutants</u></p> <p>Minimise airborne contaminants, mainly from inside sources to promote a healthy indoor environment.</p> <p>(a) Use of low volatile organic compounds (VOC) paints certified by approved local certification body.</p> <p>(b) Use of environmental friendly adhesives certified by approved local certification body.</p>	<p>Extent of Coverage : At least 90% of the total internal wall areas 1 point</p> <p>Extent of Coverage : At least 90% of the applicable areas 1 point</p>
<p><u>NRB 4-4 Indoor Air Quality (IAQ) Management</u></p> <p>Ensure that building ventilation systems are designed and installed to provide acceptable IAQ under normal operating conditions.</p> <p>(a) Provision of filtration media and differential pressure monitoring equipment in Air Handling Units (AHUs) in accordance with SS 554: Clause 4.3.4.5 and its Annex E.</p> <p>(b) Implement effective IAQ management plan to ensure that building ventilation systems are clean and free from residuals left over from construction activities. Internal surface condition tests for ACMV systems are to be included.</p>	<p>1 point</p> <p>1 point</p>
<p><u>NRB 4-5 High Frequency Ballasts</u></p> <p><i>Applicable to offices, classrooms and the like</i></p> <p>Improve workplace lighting quality by avoiding low frequency flicker associated with fluorescent lighting with the use of high frequency ballasts in the fluorescent luminaries.</p>	<p>Extent of Coverage : At least 90% of all applicable areas that are served by fluorescent luminaries 2 points</p>
<p>PART 4 – INDOOR ENVIRONMENTAL QUALITY CATEGORY SCORE :</p>	<p>Sum of Green Mark Points obtained from NRB 4-1 to 4-5</p>

Part 5 – Other Green Features	Green Mark Points
<p><u>NRB 5-1 Green Features and Innovations</u></p> <p>Encourage the use of other green features that are innovative and/or have positive environmental impact.</p> <p>Examples :</p> <ul style="list-style-type: none"> ▪ Pneumatic waste collection system ▪ Carbon footprint of development ▪ Calculation of Concrete Usage Index (CUI) ▪ Dual chute system ▪ Self cleaning façade system ▪ Conservation of existing building structure 	<p>2 points for high impact item</p> <p>1 point for medium impact item</p> <p>0.5 point for low impact item</p> <p>(Up to 7 points)</p>
<p style="text-align: center;">PART 5 – OTHER GREEN FEATURES CATEGORY SCORE :</p>	<p style="text-align: center;">Sum of Green Mark Points obtained from NRB 5-1</p>
<p>Green Mark Score (Non-Residential)</p> <p>Green Mark Score (Non-Res) = \sumCategory Score [(Part 1 – Energy Efficiency) + (Part 2 – Water Efficiency) + (Part 3 – Environmental Protection) + (Part 4 – Indoor Environmental Quality) + (Part 5 – Other Green Features)]</p> <p>where Category Score for Part 1 \geq 30 points and \sumCategory Score for Part 2, 3, 4 & 5 \geq 20 points</p>	